

Energy Consumption
and Greenhouse Gas Emissions Reporting

for the 12 month period: January to December 2024

Ontario regulation 397/11 under the Green Energy Act 2009 requires hospitals to report on their energy consumption starting in 2013.

The table below represents the 2024 Energy Consumption and Greenhouse Gas (GHG) emissions for Almonte General Hospital.

Agency Sub-sector: AcuteChronic

| Facility Description | | | | Energy Type, Amount Purchased & Consumed | | | Total (calculated in Webform) | |
|--------------------------|---|-----------------------|------------------------------|--|------------------------|-----------------|----------------------------------|------------------|
| Operation Name | Operation Type | Total Floor Area | Average Hours per week | Electricity | Natural Gas | Fuel Oil 1&2 | GHG Emissions (kg) | Energy Intensity |
| Almonte General Hospital | Facilities used for hospital purposes | 64253 ft ² | 168 | 1,353,297 kWh | 166,142 m ³ | 1,322.17 litres | 373,250.00 | 62.53 |
| Hospital Administration | Administrative offices and related facilities | 4405 ft ² | 65 | 86,825 kWh | 10,659 m3 | 84.82 litres | 23,950.00 | 58.51 |